

CERTIFICATE OF CONFORMITY TO EUROPEAN DIRECTIVES

Thermal Edge, Inc. declares that the Air Conditioners and Heat Exchangers listed below comply with the standards of the European Directives of "pressure equipment" 2016/68/EC, "low voltage equipment" 2016/35/EU, "machinery" 2006/42/EC and "electromagnetic compatibility" 2014/30/EU.

Air Conditioners:
NExxyyyy, CSxxyyyy, HCxxyyyy <u>"xxx" applies for:</u> 010, 011, 015, 020, 030, 040, 050, 060, 080, 100, 101, 120, 121, 155, 151, 180, 200, 201, 241 <u>"yyy" applies for:</u> 105, 125, 126, 205, 235, 236, 237, 385, 386, 405, 415, 485, 486, 576, D48

Heat Exchangers:
A2Axxyyzzz <u>"x" applies for:</u> D, T, C <u>"yyy" applies for:</u> 100-999 <u>"zzz" applies for:</u> 120, 230, D24, D48

These products should only be used for purposes described in the owner's manual. These products should only be serviced by trained and authorized personnel.

Applied Harmonized Standards:

- EN 378-1 through -4 Refrigerating Systems and Heat Pumps
- EN 60204-1 Electrical Equipment of Machinery
- EN 60529, IP IP Code
- EN 61000-3-11 Electromagnetic Compatibility
- EN 61000-6-2 Emission
- EN 61000-6-4 Immunity

Applied Technical Specifications:

Air conditioners have been tested and found to comply with the requirements of UL484, Room Air Conditioners rated not more than 600 volts and intended for installation in accordance with the National Electrical Code, ANSI/NFPA 70. These units employ hermetic refrigerant motor compressors with factory-charged refrigeration systems and include means for circulating air. They may also have provision for heating.

Heat Exchangers have been tested and found to comply with the requirements of UL1995, Heating and Cooling Equipment.

Equipment complies with UL508A when installed with UL508A approved industrial control panels.




Armando Lara
Quality Engineer

1751 Hurd Drive • Irving, Texas 75038 • (972) 580-0200 • (888) 580-0202 • Fax (972) 580-0277

URL: www.thermal-edge.com • Email: thermalinfo@thermal-edge.com