

EQUIPMENT DATA SPECIFICATION

AIR CONDITIONER NE050

Hazardous Location Systems



TABLE OF CONTENTS

- 1.0 SCOPE**
- 2.0 REQUIREMENTS**
- 3.0 OPTIONS**
- 4.0 ACCESSORIES**
- 5.0 CODES AND STANDARDS**

SPECIFICATION

1.0 SCOPE

This specification covers the minimum general and specific requirements for the Air Conditioner unit for electrical enclosures used in hazardous locations.

2.0 REQUIREMENTS

- Type of Heat Exchange Compressor based air conditioner
- Ambient Operating Temperature 60°F – 122°F
- Approvals and Stamps cUL_{US} (Safety), cMET_{US} (Haz Loc), CE
- Area Classification Class I, Division 2, Groups A, B, C & D, T4
- UL Type 4X
- Voltage 103.5-126.5 VAC, 60 Hz, 23.42A Inrush, 7.26A Running
207-253 VAC, 60 Hz, 19.15A Inrush, 3.76A Running
414-506 VAC, 60 Hz, 9.18A Inrush, 1.9A Running
- BTU Rating 5000 BTUH, Nominal
- Material Type 304 stainless steel housing, #4 Finish
- Construction Chassis: Rigid, insulated, closed loop
Shroud: Seam welded, sloped top, insulated
- Refrigeration Circuit Protection Electrostatic epoxy coated condenser coil
- Condensate Removal Active evaporation utilizing superheated refrigerant coil
- Refrigerant R422d
- Refrigerant Metering Thermal expansion valve

- Refrigerant Service Ports
 - High pressure
 - Low pressure
- Compressor Protection
 - Condenser high pressure switch
 - Evaporator low pressure switch
- Digital Controller
 - Controls
 - Cooling set point
 - Cooling set point differential
 - Auxiliary set point: Dry contact
 - Auxiliary set point differential
 - Display
 - Enclosure air temperature
- Compressor Head Pressure Control
 - Pressure controlled condenser fan switch
- Compressor Protection
 - Thermal/current overload switch (self-resetting)
- Condenser Filter
 - Standard: Expanded aluminum, 250 micron, 60% efficiency
- Electrical Connection
 - Terminal block
- Dimensions
 - 115 V / 230 V: 36”H x 11.8”W x 15.1”D
 - 460 V: 44.63”H x 11.8”W x 15.1”D
- Unit Weight
 - 115 V: 97 lbs.
 - 230 V: 92 lbs.
 - 460 V: 136 lbs.
- Shipping
 - Corrugated packaging and pallet
- Warranty
 - 5 years

3.0 OPTIONS

- Material Type
 - 316 stainless steel housing, #4 Finish
- Refrigeration Circuit Protection
 - Electrostatic epoxy coated evaporator coil
 - Epoxy coated refrigeration tubing
- High Capacity Condenser Filter
 - 2” Pleated, 304 Stainless steel mesh, 250 micron, 94% efficiency
- Louvered Security Filter Cover
 - 304 or 316 Stainless Steel
- Low Ambient
 - For operation at ambient temperatures below 60°F
- Dry Contact
 - Normally open
- (High Temperature Warning)

- Custom Programming Factory programming of digital controller for Celsius temperature or deviation from default settings
- Extended Temperature Probe Monitor & maintain temperature at any point inside equipment enclosure
- Remote Controller Digital controller supplied with 10 ft. cable & bracket for installation inside equipment cabinet
- Vibration Package Protects air conditioner components from effects of moderate or severe vibration

4.0 ACCESSORIES

- Replacement Filters Standard
High Capacity

5.0 CODES AND STANDARDS

- ANSI/UL 484 Room Air Conditioners (Special Purpose)
- UL508A Industrial Control Panels (Complies when installed with UL508A approved industrial control panels)
- ANSI/NFPA 70 National Electrical Code
- CSA-C22.2 No. 236-M90 Heating and Cooling Equipment
- CSA-C22.2 No. 117 Room Air Conditioners (Special Purpose)
- CAN/CSA-C22.1 Canadian Electrical Code, Part I.
- Harmonized European Standards
 - EN 378-1 through -4 Refrigerating Systems and Heat Pumps
 - EN 60204-1 Electrical Equipment of Machinery
 - EN 60529, IP IP Code
 - EN 61000-3-11 Electromagnetic Compatibility
 - EN 61000-6-2 Emission
 - EN 61000-6-4 Immunity
 - 2011/65/EU Restriction of the use of certain hazardous substances in electrical and electronic equipment
- Hazardous Location Standards
 - ANSI/ISA-12.12.01-2015 Nonincendive Electrical Equipment for use in Class I and II, Division 2 and Class III, division 1 and 2 Hazardous (Classified) Locations
 - CAN/CSA C22.2 No. 213-15 Nonincendive Electrical Equipment for use in Class I and II, Division 2 and Class III, Division 1 and 2 Hazardous (Classified) Locations